



## Certificado AENOR de Producto



042/001093

AENOR certifica que la organización

**MIGUELEZ, S.L.**

con domicilio social en AV PARROCO PABLO DIEZ, 157  
24010 TROBAJO DEL CAMINO (Leon - España)

suministra **Cable con resistencia intrínseca al fuego, destinado a circuitos de seguridad, con aislamiento polietileno reticulado y cinta de mica y cubierta de poliolefina, conductor flexible (0,6/1kV).**

conforme con UNE 211025:2020

Designación RZ1-K MICA (AS+)  
Marca Comercial MIGUELEZ AFIREFENIX  
Limitación De 1x10 mm<sup>2</sup> a 1x500 mm<sup>2</sup>; De 2x6 mm<sup>2</sup> a 2x50 mm<sup>2</sup>;  
De 3x6 mm<sup>2</sup> a 3x120 mm<sup>2</sup>; De 4x6 mm<sup>2</sup> a 4x120 mm<sup>2</sup>;  
De 5x10 mm<sup>2</sup> a 5x95 mm<sup>2</sup>.

Resistencia al Fuego PH 120

Centro de producción AV PARROCO PABLO DIEZ, 157  
24010 TROBAJO DEL CAMINO (León - España)

Esquema de certificación Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 042.01.

Este certificado anula al 042/001093, de fecha 2023-03-24

Primera emisión 2016-07-07  
Modificación 2023-05-09  
Expiración 2028-03-24

Rafael GARCÍA MEIRO  
CEO





## AENOR Product Certificate



042/001093

AENOR certifies that the organization

**MIGUELEZ, S.L.**

registered office AV PARROCO PABLO DIEZ, 157  
24010 TROBAJO DEL CAMINO (Leon - Spain)

supplies **Cable with intrinsic resistance to fire, intended for use in emergency circuits, insulated with XLPE and mica tape; polyolefin sheathed; flexible conductor (0,6/1kV).**

in compliance with UNE 211025:2020

Designation RZ1-K MICA (AS+)  
Trade Mark MIGUELEZ AFIREFENIX  
Restriction From 1x10 mm<sup>2</sup> to 1x500 mm<sup>2</sup>; From 2x6 mm<sup>2</sup> to 2x50 mm<sup>2</sup>;  
From 3x6 mm<sup>2</sup> to 3x120 mm<sup>2</sup>; From 4x6 mm<sup>2</sup> to 4x120 mm<sup>2</sup>;  
From 5x10 mm<sup>2</sup> to 5x95 mm<sup>2</sup>.

Resistance to Fire PH 120

Production site AV PARROCO PABLO DIEZ, 157  
24010 TROBAJO DEL CAMINO (León - Spain)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 042.01.

This certificate supersedes 042/001093, dated 2023-03-24

First issued on 2016-07-07  
Modified on 2023-05-09  
Validity 2028-03-24

Rafael GARCÍA MEIRO  
CEO

